

Annual Drinking Water Quality Report Addendum for 2025
Town of Pomfret Water Districts
Public Water Supply ID
Berry Road Water District NY0600369
Chestnut Road Water District NY0600395
North End Water District NY0630121

INTRODUCTION

To comply with State regulations the Town of Pomfret will be annually issuing a report describing additional water quality information of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard in 2025.

Though we are not required to test for turbidity, Fredonia Village Water System, which we purchase water from, is required to do this testing, and had one exceedance in 2025 which caused a boil order for our water districts. Likewise, the Fredonia Village Water System had two instances when their chlorination system failed and one instance of failing bacteriological samples, which also caused boil water orders for our water districts.

The information contained in this report is a supplement to the report that you received from the Village of Fredonia. If you did not receive information from Fredonia, please feel free to contact the Village at (716) 679-2302, or find a copy of the report on the Village's website.

WHERE DOES OUR WATER COME FROM?

Water Customers residing in all three water districts receive water from the Village of Fredonia. The Town of Pomfret does not provide any additional treatment to the water.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, total trihalomethanes, Haloacetic acids and Lead and Copper. The table presented below depicts which compounds were detected in your drinking water.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Chautauqua County Health Department at 716-753-4481.

Table of Detected Contaminants - Berry Road Water District

Contaminant	Violation	Date of Sample	Level Detected	Unit Measure-ment	Regulatory Limit MCL/AL	MCLG	Likely Source of Contamination
DISINFECTION BYPRODUCTS							
Haloacetic Acids	No	Quarterly (2025)	Avg. = 4.73 Range= 1.1 - 5.8	ug/l	60 (MCL)	N/A	By-products of drinking water chlorination.
Total Trihalomethanes	No	Quarterly (2025)	Avg. = 49.48 Range= 28.9 - 69.0	ug/l	80 (MCL)	N/A	By-products of drinking water chlorination. TTHM's are formed when source water contains large amounts of organic matter.
INORGANIC CONTAMINANTS							
Lead (1)	No	8/12/25	1.75; Range= ND - 2.0	ug/l	15 (AL)	0	Corrosion of household plumbing systems; Erosion of natural Deposits



Copper (2)	No	8/12/25	0.643; Range= 0.0237 - 0.847	mg/l	1.3(AL)	1.3	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Chlorine Residual	No	Monthly (2025)	Avg.= 0.49 Range=0.02 - 1.51	mg/l	4.0 (MCL)	N/A	Water additive used to control microbes.

Notes:
1 – The level presented represents the 90th percentile of the 5 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead values detected at your water system. In this case, 5 samples were collected at your water system and the 90th percentile value was determined by averaging the two highest results found (2.0 ug/L and 1.5 ug/L). The action level for lead was not exceeded at any of the sites tested.

2 – The level presented represents the 90th percentile of the 5 sites tested. Again, 5 samples were collected at your water system and the 90th percentile value was determined by averaging the two highest results found (0.847 mg/L and 0.438 mg/L). The action level for copper was not exceeded at any of the sites tested.

Table of Detected Contaminants - Chestnut Road Water District

Contaminant	Violation	Date of Sample	Level Detected	Unit Measure -ment	Regulatory Limit MCL/AL	MCLG	Likely Source of Contamination
DISINFECTION BYPRODUCTS							
Haloacetic Acids	No	Quarterly (2025)	Avg.= 21.7 Range= 5.0 – 40.7	ug/l	60 (MCL)	N/A	By-products of drinking water chlorination.
Total Trihalomethanes	No	Quarterly (2025)	Avg.= 49.9 Range= 25.5 - 74.7	ug/l	80 (MCL)	N/A	By-products of drinking water chlorination. TTHM's are formed when source water contains large amounts of organic matter.

INORGANIC CONTAMINANTS

Lead (1)	No	8/15/25 – 9/23/25	2.15; Range= ND – 2.2	ug/l	15 (AL)	0	Corrosion of household plumbing systems; Erosion of natural Deposits
Copper (2)	No	8/15/25 – 9/23/25	0.372; Range= 0.0643 – 0.432	mg/l	1.3(AL)	1.3	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Chlorine Residual	No	Monthly (2025)	Avg.= 0.47 Range= 0.08 - 1.16	mg/l	4.0 (MCL)	N/A	Water additive used to control microbes.

Notes:
1 – The level presented represents the 90th percentile of the 5 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead values detected at your water system. In this case, 5 samples were collected at your water system and the 90th percentile value was determined by averaging the two highest results found (2.2 ug/L and 2.1 ug/L). The action level for lead was not exceeded at any of the sites tested.

2 – The level presented represents the 90th percentile of the 5 sites tested. Again, 5 samples were collected at your water system and the 90th percentile value was determined by averaging the two highest results found (0.432 mg/L and 0.312 mg/L). The action level for copper was not exceeded at any of the sites tested.

Table of Detected Contaminants - North End Water District

Contaminant	Violation	Date of Sample	Level Detected	Unit Measure -ment	Regulatory Limit MCL/AL	MCLG	Likely Source of Contamination
DISINFECTION BYPRODUCTS							
Haloacetic Acids	No	Quarterly (2025)	Avg.= 22.73 Range=1.1 – 43.6	ug/l	60 (MCL)	N/A	By-products of drinking water chlorination.
Total Trihalomethanes	No	Quarterly (2025)	Avg.= 64.35 Range= 32.8 – 86.0	ug/l	80 (MCL)	N/A	By-products of drinking water chlorination. TTHM's are formed when source water contains large amounts of organic matter.

INORGANIC CONTAMINANTS

Lead (1)	No	8/15/25 – 9/23/25	4.6; Range= ND – 6.4	ug/l	15 (AL)	0	Corrosion of household plumbing systems; Erosion of natural Deposits
----------	----	-------------------	----------------------------	------	---------	---	---

Copper (2)	No	8/15/25 – 9/23/25	0.646; Range= 0.0104 – 0.899	mg/l	1.3(AL)	1.3	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Chlorine Residual	No	Monthly (2025)	Avg.= 0.43 Range= 0.01- 1.52	mg/l	4.0 (MCL)	N/A	Water additive used to control microbes.

Notes:

1 – The level presented represents the 90th percentile of the 5 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the lead values detected at your water system. In this case, 5 samples were collected at your water system and the 90th percentile value was determined by averaging the two highest results found (6.4 ug/L and 2.8 ug/L). The action level for lead was not exceeded at any of the sites tested.

2 – The level presented represents the 90th percentile of the 5 sites tested. Again, 5 samples were collected at your water system and the 90th percentile value was determined by averaging the two highest results found (0.899 mg/L and 0.393 mg/L). The action level for copper was not exceeded at any of the sites tested.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant that is allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).


WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State. Lead and copper were detected within the system but of 15 samples collected, none were found exceeding the action levels. We are however required to present the following information on Lead in drinking water:

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. The Town of Pomfret is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact The Town of Pomfret at 716-672-7496. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During 2025, our



system was in compliance with all applicable State drinking water operating, monitoring, and reporting requirements.

INFORMATION ON LEAD SERVICE LINE INVENTORY

A Lead Service Line (LSL) is defined as any portion of pipe that is made of lead which connects the water main to the building inlet. An LSL may be owned by the water system, owned by the property owner, or both. The inventory includes both potable and non-potable SLs within a system. In accordance with the federal Lead and Copper Rule Revisions (LCRR) our system has prepared a lead service line inventory and have made it publicly accessible by checking the Town of Pomfret website townofpomfretny.gov or Contacting the Town Clerks Office (716) 672-7496 and/or visiting the following website: <https://health.data.ny.gov/Health/New-York-State-Lead-Service-Line-Inventory-Map/fkii-zkcq>

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

INFORMATION FOR NON-ENGLISH-SPEAKING RESIDENTS

Spanish

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

French

Ce rapport contient des informations importantes sur votre eau potable. Traduisez-le ou parlez en avec quelqu'un qui le comprend bien.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

The Town of Pomfret encourages water conservation. A few simple steps will help preserve our resources and save you money. You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ♦ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ♦ Turn off the tap when brushing your teeth.
- ♦ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- ♦ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- ♦ Install water saving toilets, low flow shower heads and faucets.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.

