

CITY OF BRILLION TREATMENT FACILITY OVERFLOW PUBLIC NOTICE

Notice is hereby given pursuant of s. NR 210.21 (5) that the City of Brillion Wastewater Treatment Plant experienced a Treatment Facility Overflow (TFO) event on December 19th, 2021.

The TFO is the result of excessive foaming of the aeration basins which overflowed onto the surrounding grass. Plant staff responded to the foaming event by adding defoamer and using a water spray to knock down the foam which mitigated the impacts to public health, the environment, and property. Plant staff was unable to identify the source of the foam. The TFO event was reported to the Wisconsin Department of Natural Resources pursuant of NR 210.21 (4).

Published by the Authority of the City of Brillion.