



**Brillion Utility**  
201 N. Main Street  
Brillion, WI 54110  
Phone (920) 756-2850

**CITY OF BRILLION TREATMENT FACILITY AND SANITARY SEWER OVERFLOW**  
**PUBLIC NOTICE**

Notice is hereby given pursuant of s. NR 210.21 (5) that the City of Brillion experienced a Sanitary Sewer Overflow on 4/9/2026

The SSO was the result of a mechanical failure at Main Lift Station in Peters Park. Utility staff and outside contractors responded to the mechanical failure. The mechanical failure was repaired and the lift station was put back into normal operation within 2 hours. Utility staff and the Department of Public Works mitigated the impacts to public health, the environment, and property. The SSO event was reported to the Wisconsin Department of Natural Resources pursuant of NR 210.21 (4).

Published by the Authority of the City of Brillion.