



Brillion Utility
201 N. Main Street
Brillion, WI 54110
Phone (920) 756-2850

CITY OF BRILLION TREATMENT FACILITY OVERFLOW PUBLIC NOTICE

Notice is hereby given pursuant of s. NR 210.21 (5) that the City of Brillion Wastewater Treatment Plant experienced a Treatment Facility Overflow (TFO) event on April 13th 11:45 p.m. to April 14th 7:00 a.m.

The TFO is the result of excessive precipitation on already saturated ground which inflowed and infiltrated into the sanitary collection sewer system hydraulically exceeded the design capacity of the wastewater treatment plant. Plant staff responded to the high flow conditions which mitigated the impacts to public health, the environment, and property. The TFO event was reported to the Wisconsin Department of Natural Resources pursuant of NR 210.21 (4).

Published by the Authority of the City of Brillion.